

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225294
Address: 5031 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Monday, November 13, 2023

Informational:
1 Misc 1-hr fire barrier at space 105 underneath stair:
-GB installed above ceiling line inside rm 105 need to be mud&taped. Complete ceiling framing for 3 layers of 5/8" GB. Screw pattern of GB outside rm 105-OK

Comments: