

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233918
Address: 2234 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Robb Popp	Failed	Tuesday, November 14, 2023

Corrective Action Required:

1	Misc	-Meter to be 14" to 18" to top of riser -Provide suitable amount of gravel in bottom of pit
---	------	--

Comments: