

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234774

Address: 3734 SW MARYVILLE PL, LEES SUMMIT, MO 640823736 SW MARYVILLE PL, LEES SUMMIT, MO  
640823738 SW MARYVILLE PL, LEES SUMMIT, MO 640823740 SW MARYVILLE PL, LEES  
SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Residential</b>	Kyle Beard	Failed	Tuesday, November 14, 2023

Corrective Action Required:

1	Miscellaneous Correction	2 inch drain in 3736 by garage wall is not fully supported underneath by gravel
---	-----------------------------	--

**Comments:**