

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20225681  
Address: 2405 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, November 14, 2023

Corrective Action Required:

1	Misc	-fire block S garage wall to ceiling space and furr down -fireblock N garage wall in furr downs -fire block E garage wall into furr down -roof boots to be installed and/or holes covered see bed -fire block pantry furr down -uncover covered rear deck for inspection -address all holes drilled through floor joist above hearth room and kitchen closer than 2" to one another add where missing -provide support and hold down for ridge above bed 4 to plans 2 2x4 each side and 2 h2.5 each side -missing steel columns in basement (have design professional address if not required)
---	------	--

**Comments:**