

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231599  
Address: 1051 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, November 14, 2023

Corrective Action Required:

2	Misc	<ul style="list-style-type: none"><li>- Provide strap extortion corner kitchen at cut studs</li><li>- Strap top plate master bedroom at entry</li><li>- Provide Boca plates masters bath at vanities</li><li>- Solid block exterior wall master bedroom between window and entry</li><li>- Support gas line first floor powder room</li><li>- Anchor bolts to be in middle third of plate, garage</li><li>- Provide scuppers for roof deck</li><li>- Complete both fireplaces</li><li>- Purlin struts to be 4' on center</li></ul>
---	------	--

**Comments:**