

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20223840  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Tuesday, November 14, 2023

Corrective Action Required:

1	Misc	-Pay all fees -Provide backflow devices at all carbonated beverage machines, coffee makers, ice machines and non carbonated dispensers (ASSE 1022 at carbonated machine) -Install screens at rooftop storm drains
---	------	---

**\*\*OK TO STOCK AND INSTALL REST OF EQUIPMENT AND ACCESSORIES. DO NOT OCCUPY**

**Comments:**