

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20225393  
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mitchell Schwarz	Partial	Tuesday, November 14, 2023

Corrective Action Required:  
1 Misc Second floor bath only. Install bath vents

Corrective Action Required:  
2 Misc First floor Inspected.  
-dayroom border of drop ceiling  
-bathrooms  
-conference room border of drop ceiling  
-captain office border of drop ceiling  
-covered patio on W side  
-east patio/entrance  
  
-secure MC within 12" of boxes  
10/11/23 Mitchell Schwarz

Informational:  
3 Misc Under stairs okay to first layer rock

**Comments:**