

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232219
Address: 3250 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, November 15, 2023

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- upload 3 rd party footing report- Nail off studs exterior corner at master closet- Complete exhaust vents at master bathroom- Fb penetrations at return air kitchens/ master bedroom- Security blocking to be 3 stud bays out at front entrance- Complete bathroom vent first floor near laundry- Protect NM garage near line set- Provide attic access garage- Fb top plate garage wall above owners entrance- Provide washers and nuts for anchor bolts at garage portal frame- Missing roof boot for radon- Nail off studs at exterior corner second floor storage near stairs- Provide roof boot for DWV second floor- Complete all bathroom vents second floor- Provide attic access second floor |
|---|------|--|

Comments: