

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221050
Address: 3112 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Wednesday, November 15, 2023

Informational:	
1 Misc	11-15-23 Dustin A, DW is formed. Aggregate is compacted and depths are in compliance . Will need to maintain ADA specs through approach. Approved to pour.

Comments: