



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLAN REVIEW CONDITIONS

October 24, 2023

Baby Bump Imaging
1002 SW Blue Parkway
Lees Summit, MO 64063

Permit No: PRCOM20234451
Project Title: BABY BUMP IMAGING
Project Address: 612 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063
Parcel Number: 61330168900000000
Location: RNG-31 TWP-47 SEC-06 PT SW 1/4 DAF: BEG AT A PT 1150' W OF SE COR SD SW 1/4 TH N 28' M/L TO N ROW LI OF 3RD ST & TRU POB TH CONT N 220' TH E 130' TO SW COR LOT 58 ROBIN HILLS TH N 125' TO S ROW LI OF
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR ULTRASOUND CLINIC WITH COFFEE BAR

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Approved with Conditions

1. 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of one, 2A,10B,C fire extinguisher at a conspicuous location. Verified at inspection.

2. All existing conditions subject to inspection and correction at time of occupancy.

Fire Plan Review

Reviewed By: Jim Eden

Approved with Conditions

1. 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of one, 2A,10B,C fire extinguisher at a conspicuous location. Verified at inspection.

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

3. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 797-7162. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is informational.

9/22/23 - not addressed

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 797-7162. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is informational.

2. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 797-7162. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is informational.

3. 2018 IBC 2902.3.1 Access. The route to the public toilet facilities required by Section 2902.3 shall not pass through kitchens, storage rooms or closets. Access to the required facilities shall be from within the building or from the exterior of the building. All routes shall comply with the accessibility requirements of this code. The public shall have access to the required toilet facilities at all times that the building is occupied.

Action required: Relocate restroom or redesign space to comply. Any new or relocated restroom and/or restroom components must be brought up to all modern codes, including accessibility.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.