

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234451
Address: 612 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Thursday, November 16, 2023

Corrective Action Required:

1	Misc	-Secure mc within 12" of boxes -Support all cables off of grid -NM cables not allowed above drop ceiling -Wiring methods to lights in patient care areas to comply with NEC 517
---	------	--

Comments: