

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20225393  
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector:       | Outcome: | Date:                     |
|----------------------------------|------------------|----------|---------------------------|
| <b>Rated Assembly Inspection</b> | Mitchell Schwarz | Partial  | Friday, November 17, 2023 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | First layer, screw pattern walls under stairs<br>Fire caulking directly under stairs<br><br>1st, 2nd and 3rd layer under stairs ceiling |
|---|------|---|

**Comments:**