



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113956, Building Permit - Commercial

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Not Ready	Wednesday, July 27, 2011

Corrective Action Required

1 MISC

CONNECTION OF GROUNDING ELECTRODE CONDUCTOR TO
GROUNDING ELECTRODE NOT FOUND.

Corrective Action Required

2 MISC

LOCATION ADDRESS NOT FOUND PERMANENTLY AFFIXED TO
SERVICE ENCLOSURE.

Comments: