

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231857  
Address: 4809 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Alex Fischer	Failed	Monday, November 20, 2023

Corrective Action Required:

1	Misc	Label all non gfci's in garage -Step/threshold to patio exceed 7 3/4 inches -Water heater is not wired -Missing spindles at stairs to basement
---	------	---

**Comments:**