

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20232719  
Address: 1534 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector: | Outcome: | Date:                     |
|---------------------------------------------|------------|----------|---------------------------|
| <b>Gas Service Inspection - Residential</b> | Kyle Beard | Failed   | Monday, November 20, 2023 |

Corrective Action Required:

|   |                          |                          |
|---|--------------------------|--------------------------|
| 1 | Miscellaneous Correction | Gas line is not grounded |
|---|--------------------------|--------------------------|

**Comments:**