

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20232433  
Address: 2122 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector: | Outcome:  | Date:                           |
|------------------------|------------|-----------|---------------------------------|
| <b>Erosion Control</b> | Kyle Beard | Not Ready | Wednesday,<br>November 22, 2023 |

Corrective Action Required:

|   |                             |                                                                                                                                                                                                                                                                                                                                   |
|---|-----------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Miscellaneous<br>Correction | Lee's Summit June 2021 Erosion and sediment control standards for single family residential states ESC BMP will be completed by the time plumbing rough-in inspection is requested. Full property erosion control and gravel spread from the street to the dwelling are required before scheduling inspections<br>11/21/23 KBEARD |
|---|-----------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Corrective Action Required:

|   |                             |                                                                                                                                                  |
|---|-----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| 2 | Miscellaneous<br>Correction | Gravel is not spread. Erosion control is not ready and failed. Walk your job site before calling in for an inspection.<br>11/22/23 KBEARD 8:21AM |
|---|-----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**