

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234049

Address: 2208 SW OSAGE DR, LEES SUMMIT, MO 640822210 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Wednesday, November 22, 2023

Corrective Action Required:

1	Miscellaneous Correction	CSPF strap on the interior does not attach to the top plate. CSPF needs to be fastened to both top plates with IRC approved fasteners.
		Gravel and mud in the street needs to be cleaned up before scheduling your re inspection of the CSPF 11/22/23 KBEARD

Comments: