

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234049

Address: 2208 SW OSAGE DR, LEES SUMMIT, MO 640822210 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Wednesday, November 22, 2023

Corrective Action Required:

1 Miscellaneous Erosion control is required and needs to be maintained until occupancy
Correction

Corrective Action Required:

2 Miscellaneous Full erosion control is not in place. CLEAN the street of all mud and gravel. No
Correction inspections will proceed until erosion control and removal of debris from
street are completed
11/06/23 KBEARD

Corrective Action Required:

3 Miscellaneous Full erosion control is still not in place. Clean street of mud and gravel, more
Correction gravel may be needed to keep street clean from mud. Some erosion control
is missing or torn down.

Full erosion control must be in place, mud and gravel in the street needs to
be cleaned up before further inspections can be conducted.
11/22/23 KBEARD

Comments: