

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20233917  
Address: 2230 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Not Ready	Wednesday, November 22, 2023

Informational:

1	Misc	11/11/23 garage portal only
---	------	--------------------------------

Corrective Action Required:

2	Misc	11/21/23 **Not ready -provide City approved, stamped plans for inspection -Provide bocca plate at top plate in laundry furout wall -Missing nails at joist hangers in Kitchen -Complete covered deck -Install egress window -Seal gaps in top of verticle fireblocking in rec room -Sister all over notched studs at exterior basement walls -Fireblock wall space to stair landing -Provide anchor bolts within 12" of plate breaks in basement
---	------	---

\*\*INSPECTION INCOMPLETE

**Comments:**