

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234451
Address: 612 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Passed	Wednesday, November 22, 2023

Informational:

1 Misc

- Support all cables off of grid
- NM cables not allowed above drop ceiling
- Close open boxes

****Items above will be addressed on future tenant improvements, all new work for current scope of work is complete and approved**

Comments: