

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX: 816-969-1201

## **Inspection Summary**

Permit #: PRCOM20110759, Building Permit - Commercial Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Rated Assembly Inspection	John Borns	Partial	Thursday, July 28, 2011	
Partial Correction 1 MISC	FUTL COV	RATED ASSEMBLY @ NORTH, WEST, & SOUTH WALLS @ FUTURE ELEVATOR SHAFT: FRAMING + LINER BOARD OK TO COVER WHEN READY; 1ST LAYER OF 1/2" GWB; 2ND LAYER OF 1/2" GWB		
Partial Correction 2 MISC	OK TO TAPE, MUD, AND FIRE-SEAL FOLLOWING RATED WALLS: CORRIDOR FACE OF EAST WALLS OF SPACES 19, 29;			
In-wall Inspection	John Borns	Partial	Thursday, July 28, 2011	
Partial Correction 1 MISC	OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS @ LOCATIONS: 01 E WALL; 5; 06; 10; 15; 19; 21; 25; 27; 29; 38; 40; 71; 73; 74; 75; 77; 3; 4; 8; 11; 13; 17; 23; 31; 80; 83; 84			

Comments: