

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226005
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Patrick Schonfeldt	Passed	Monday, November 27, 2023

Informational:

1 Misc

9-13-23 PS Partial inspection on pex service line from building to meter well location. OK to cover partial inspected.

9-13-23 PS Water service approved

Do not cover main - Service line at 1828 SW River Run was struck off main excavating for pool house service line and is damaged. This will need to be addressed with new copper line bored across street before cover

10-6-23 PS Per Brent with water issues for service line at 1828 SW River Run have been resolved

Comments: