

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232719
Address: 1534 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Tuesday, November 28, 2023

Corrective Action Required:

2	Miscellaneous Correction	LIB in bedroom 2 is missing nails Truss tie down straps in great room by fireplace are all missing two nails at the top Truss tie down can be bent over the bottom truss cord and nailed down utilizing the complete truss bracket
---	--------------------------	--

Comments: