CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221108

Address: 3104 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Alex Fischer Failed Tuesday, November

Residential 28, 2023

Partial Correction:

1 Misc TCO expiered 7/7/23

Submit TCO extension request form

-2 1/2" through bolts at each deck post to beam connection (R507.5.1) PROVIDE DOCUMENTATION THAT LEDGER LOCKS MEET THE CODE

REQUIREMENT

Comments: