

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230570
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, November 28, 2023

Corrective Action Required:

1	Misc	Exterior wall GB and column footing-OK below: -A.2/1.2 to 5.2; cont. to A.2/8 to F.4/7 -A.2/1.2 to F.5/3; cont. to G.5/2.3 -Remaining footing All interior column pads-OK Exterior GB and column pads-OK below: -xA/1&1.5&3.5; x2/C.5&D.5; x1/C.5 to D.5 -Trash enclosure -Chiller&generator
---	------	--

Comments: