

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232995
Address: 2768 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, November 28, 2023

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Complete solid blocking at garage wall soffit top plate |
| | | - Nail off studs at exterior corner of dining room kitchen side |
| | | - nail 3 by 2x4s stud packs on both sides under cat walk and basement stairs |
| | | - Window at lower landing to be tampered glass |

Comments: