

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225294
Address: 5031 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Thursday, November 30, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Connection of the grounding electrode conductor to the grounding rod shall be by a listed grounding clamp listed to be directly buried into soil. Installation of the grounding clamp shall be per listing of the product. NEC 250.70-Provide a continuous grounding electrode conductor from the electrode grounding plate to the service grounded conductor/bus bar-Install an 2/0 AL EGC in each set of parallel conductors of feeders going to MDP and generator-Install bigger lug to accomodate the 2/0 EGCs inside the MDP-Complete wiring inside CT cabinet
---	------	--

Comments: