

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233616

Address: 2202 SW OSAGE DR, LEES SUMMIT, MO 640822204 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Kyle Beard	Passed	Thursday, November 30, 2023

Informational:

1	Miscellaneous Correction	Two deck piers were inspected at 2202 SW Osage for a rear deck without stairs
---	--------------------------	---

Comments: