

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20230660
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection	Bobby Richest	Passed	Friday, December 01, 2023

Informational:

1	Misc	10-27-23 BR Contractor install backflow vault.
		10-31-23 BR Contractor install fire line from vault to building.
		11-6-23 BR Contractor install service line from water tap to building.
		11-30-23 BR Contractor performed Hydrostatic test on the fire line & domestic water line with pass to LS specifications..

Comments: