

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20225681  
Address: 2405 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Passed	Monday, December 04, 2023

Partial Correction:

1	Misc	-uncover covered rear deck for inspection -address all holes drilled through floor joist above hearth room and kitchen closer than 2" to one another add where missing
---	------	---

Okay to insulate

**Comments:**