CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20235090 Address: 700 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	Dustin Agcopra	Passed	Monday, December 04, 2023
Informational:			
1 Misc	11-29-23 Dustin A, Proof roll. Aggregate is compacted and geo grid is installe		

11-29-23 Dustin A, Proof roll. Aggregate is compacted and geo grid is installed . Passed

Comments: