## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20233692

Address: 2626 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Erosion Control** Shawn Hoffman Failed Tuesday, December

05, 2023

Corrective Action Required:

1 Misc - No pressure on gauge

- gas line not bonded

**Comments:**