

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20234293  
Address: 1220 NW MAIN ST, Unit:A, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Tuesday, December 05, 2023

Corrective Action Required:

1	Misc	-Bolts at racking not per plan; have engineer approve shorter expansion anchors used throughout, or install Hilti KWIK-X 1/2 anchors with 4 1/4" embedment per plan
---	------	---

**Comments:**