

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216099  
Address: 4728 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Khanh Nguyen	Failed	Wednesday, December 06, 2023

**Corrective Action Required:**

1	Misc	-Ground service per code **Inside the service disconnect, connect the ufer grounding conductor to the service grounded bus bar at right side. NEC 250.24
		-Install an insulation bushing to the protect the SE cable at entrance into the service disconnect enclosure
		-Install insulating bushing at sub-panel

**Comments:**