

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216100
Address: 4813 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, December 06, 2023

Corrective Action Required:

1	Misc	-Provide attic access to roof space **Staple wiring along the joists and away from attic access opening. Wiring running across the top of joists where within 6 ft if the attic access opening shall be protected with running board
		-Interior braced wall at kitchen /garage wall will be per GB method. Call for inspection of nailing pattern when ready

**OK TO INSULATE

Comments: