

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230107
Address: 1501 NE US 40 HWY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, December 06, 2023

Corrective Action Required:

1	Misc	-Min 12" cover of underground DVW pipes is required -Support pipe at maximum four ft interval -Provide 4" building drain as shown on plan. Submit revised as-built drawing of plumbing -Inspection of the sewer pipe to the grease trap is required
---	------	--

****12/6/23**-The crawspace walkway is now narrowed , making impossible for the inspector to inspect the plumbing. Verification of the plumbing compliance shall be provided.

Comments: