

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233629
Address: 3215 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Mitchell Schwarz	Failed	Thursday, December 07, 2023

Corrective Action Required:

1	Misc	Plans call for 24"x36" piers in the center 2
		Outside corner piers okay at 18"x36"

Comments: