

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231716

Address: 2012 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822014 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822016 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822018 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Friday, December 08, 2023

Corrective Action Required:

1	Miscellaneous Correction	All units passed for TCO Exterior of each property has not been inspected 12/04/23 KBEARD
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	-Seal all exterior penetrations -Install anti siphon valve on exterior ac units -permit is required for lawn irrigation system already installed
---	--------------------------	--

Comments: