

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225745
Address: 3219 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Friday, December 08, 2023

Corrective Action Required:

1	Misc	-Driveway inspection pending -Piers poured without inspection -Install code compliant gaurdrail and handrail at deck -Provide security screws at hinges and strikes of exterior doors -Dishwasher to be GFCI protected -Install splash blocks -sewer tracer wire box to be at grade -Water meter to be 14"-18" to top of can -Stair riser is over 7.75" and varies more than 3/8" at top riser of basement stairs
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: