

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233906
Address: 3340 NE RALPH POWELL RD, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Passed	Monday, December 11, 2023

Informational:

1 Misc

Existing non-compliance: materials within plenum space (Wood sheathing, plastic tubing, etc) not meeting requirement of flame spread index not more than 25 and smoke develop index not more than 50.

-All new low-voltage cables within plenum space shall be plenum-rated

Comments: