

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222783  
Address: 1231 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	John Jackson	Partial	Monday, December 11, 2023

Informational:  
1 Misc 03/03/23 Friday JMJ  
Erosion control appears to be functioning. I will remind the contractor to clean the adjacent streets, because of mud coming from the tires of vehicles.

Informational:  
2 Misc 08/03/23 Thursday JMJ (Kadean)  
Erosion control appears to be functioning.

09/06/23 Wednesday JMJ (Kadean)  
Erosion control appears to be functioning.

12/11/23 Monday JMJ  
Erosion was blown out on the Northwest side of building #3.

**Comments:**