

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216100
Address: 4813 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Monday, December 11, 2023

Corrective Action Required:

1	Misc	-Interior braced wall at kitchen /garage wall will be per GB method. Call for inspection of nailing pattern when ready
---	------	--

**OK to rock. Call for nailing pattern inspection of the braced wall GB when ready (7" on center)

Comments: