

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221049

Address: 808 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
806 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
64064804 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Monday, December 11, 2023

Informational:

1 Misc

6-8-23 NS Site visited and driveway and sidewalk are not ready. I will schedule out for a couple months.

11-7-23 Dustin A, visited site. Not ready . Will check back in few weeks

12-11-23 Dustin A, dw is formed on all 3 units . Will need to maintain ADA slopes through approach. It is framed and aggregate is compacted. approved to pour.

**Comments:**