

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222414
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Robb Popp	Failed	Tuesday, December 12, 2023

Corrective Action Required:

1	Misc	-Remove bonding screw from panel -Install equipment ground bus bar and seperate grounding and nueutral conductors -Provide lockout or disconnect for scoreboard ciruit -Provide 36" working space in front of equipment
---	------	--

Comments: