

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233055  
Address: 3258 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, December 12, 2023

Corrective Action Required:

1 Misc

- Brackets holding garage door track to be within 18" of bottom of track
- Fire block penetration at top plate garage/laundry
- Strap top plate bedroom 2 closet, less than 24" overlap
- Solid block top plate double wall and height change at office and bath tub
- Security blocking 3 bays out at front door
- Nail off studs corner top third, great room front between windows
- Steel column pad G in basement to be 4" (A 3.5" installed )

**Comments:**