

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215559

Address: 451 SE OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line - Hydrostatic Test	Patrick Schonfeldt	Passed	Tuesday, December 12, 2023

Informational:

1	Misc	12-12-23 PS Contractor performing hydrostatic test on fireline, test started 10:30 AM
		12-12-23 PS Hydrostatic test completed at 12:30 PM, hydro test passed

Comments: