

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225393
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mitchell Schwarz	Failed	Tuesday, December 12, 2023

Corrective Action Required:
1 Misc Second floor bath only. Install bath vents

Corrective Action Required:
2 Misc First floor Inspected.
-dayroom border of drop ceiling
-bathrooms
-conference room border of drop ceiling
-captain office border of drop ceiling
-covered patio on W side
-east patio/entrance

-secure MC within 12" of boxes
10/11/23 Mitchell Schwarz

Informational:
3 Misc

-203 to be completed
-202 secure conduit with in 12" of box
-east end of hall to be completed
-support mc at E fire pole
-213 close boxes and fill unused knockout.
-212 okay

- 211 okay
- 210 okay
- 209 okay
- 205 complete duct work
- 207 to be completed
- 208 okay
- hall duct work To be seal

Comments: