

## FIRE DEPARTMENT

## Prevention Division (816)969-1300

## **PLANS REVIEW CONDITIONS**

Permit No: PRCOM20230570 Date: December 12, 2023

Project Title: LEES SUMMIT MEDICAL CENTER - Applicant:

AMBULATORY SURGERY CENTER

Location: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

Type of Work:

Occupancy Group: I-2

Description: NEW AMBULATORY SURGICAL

CENTER BUILDING

Construction Type: Type IIB (Unprotected)

Map Page:

<NO CONTACT NAME AVAILABLE>

American Fire Sprinkler Corporation

6750 W 47th Terrace

Kansas, MO 66203

<NO CONTACT INFORMATION AVAILABLE>

Primary: (913) 722-6900 Ext: 125

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Jim Eden Released for Construction per Listed Conditions

1. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Received November 28,2023.

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow tests.

3. Provide remote dry system inspectors test, not shown. Verified at inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable Cit Codes and Ordinances.