

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	Robb Popp	Partial	Wednesday, December 13, 2023

Informational:	
1 Misc	12-13-23 -Submit change to detail of concrete walls in place of masonry walls at trash enclosure. Rebar witnessed is #4 at 12" oc horizontal and vertical

Comments: