

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20231814  
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Khanh Nguyen	Failed	Wednesday, December 13, 2023

Corrective Action Required:

1	Misc	-Clean out debris and loose dirt from pier holes -Provide 6 ft of pier burial depth -Raise rebar min 3" off soil -Install grounding rods straight down.
---	------	--

**Comments:**